



## Standard Specification for Dielectric Footwear<sup>1</sup>

This standard is issued under the fixed designation F 1117; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon ( $\epsilon$ ) indicates an editorial change since the last revision or reapproval.

### 1. Scope

1.1 This specification covers acceptance testing of dielectric overfoot and overshoe footwear designed to provide additional isolation or insulation of workers if in accidental contact with energized electrical conductors, apparatus, or circuits.

1.2 Three styles of overshoe footwear are provided and are designated as rubbers, boots, and galoshes.

### 2. Referenced Documents

#### 2.1 *ASTM Standards:*<sup>2</sup>

F 819 Definitions of Terms Relating to Electrical Protective Equipment for Workers

F 1116 Test Method for Determining Dielectric Strength of Dielectric Footwear

### 3. Terminology

3.1 *Definitions*—Definitions pertaining to electrical protective equipment may be found in Definitions F 819.

#### 3.2 *Definitions of Terms Specific to This Standard:*

3.2.1 *user*—as used in 4.3.1, the entity employing the actual worker(s) utilizing the equipment; if no separate employer, then the individual.

### 4. Significance and Use

4.1 This specification covers the minimum electrical properties of dielectric footwear guaranteed by the manufacturer and the detailed procedures by which such properties are to be determined. The purchaser may, at his option, perform or have performed these tests in order to verify the guarantee. Claims for failure to meet the specification are subject to verification by the manufacturer.

4.2 Electrical contact injuries to workers may involve a current path through the feet of the worker. The footwear covered by this specification is dielectrically rated to provide additional isolation or insulation to the worker.

4.3 Work practices vary from user to user depending upon many factors. These may include, but are not limited to, operating system voltages, construction design, work procedures and techniques, weather conditions, etc. Therefore, except for the restrictions set forth in this specification because of design limitations, the use and maintenance of this equipment is beyond the scope of this specification.

4.3.1 It is common practice and the responsibility of the user of this type of protective equipment to prepare complete instructions and regulations to govern the correct and safe use of such equipment.

### 5. Classification

5.1 Styles of overshoe footwear covered under this specification shall be designated as follows:

5.1.1 *Rubbers*, designed to be worn over existing footwear and to cover only the foot of the worker.

5.1.2 *Boots*, designed to be worn over existing footwear and to cover the foot and lower leg of the worker to below the knee.

5.1.3 *Galoshes*, designed to be worn over existing footwear and to cover the foot and lower leg of the worker to below the knee and having fasteners to close the folded front flaps.

### 6. Ordering Information

6.1 Orders for footwear under this specification should include the following information:

6.1.1 Style,

6.1.2 Size, and

6.1.3 Color.

### 7. Manufacture and Marking

7.1 The construction shall be such that the footwear has a specified minimum dielectric strength when tested as specified in Test Method F 1116.

7.2 Each article of footwear shall be marked clearly and permanently with the name of the manufacturer or supplier, ASTM F1117, size, and ac voltage rating.

<sup>1</sup> This specification is under the jurisdiction of ASTM Committee F18 on Electrical Protective Equipment for Workers and is the direct responsibility of Subcommittee F18.15 on Worker Personal Equipment.

Current edition approved Nov. 1, 2003. Published January 2004. Originally approved in 1993. Last previous edition approved in 1993 as F 1117-93.

<sup>2</sup> For referenced ASTM standards, visit the ASTM website, [www.astm.org](http://www.astm.org), or contact ASTM Customer Service at [service@astm.org](mailto:service@astm.org). For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

7.3 The required information shall be on a label which shall be applied to either the inside or outside of the footwear in such a manner as to not affect the dielectric property of the footwear.

## **8. Electrical Requirements**

8.1 Each article of overshoe footwear shall be given a proof test and shall withstand the 60-Hz ac proof-test voltage (rms value) or the dc proof-test voltage (average value) specified in Test Method F 1116.

## **9. Sampling**

9.1 Each article of footwear in a lot or shipment shall be subject to inspection and test to meet the requirements of Sections 7, 8.1, and 12.

## **10. Guarantee**

10.1 The manufacturer or supplier shall replace, without charge to the purchaser, unused footwear which, at any time within a period of nine months from date of initial delivery of shipment to the purchaser or his designee, fail to pass the tests in this specification. This guarantee will be binding on the manufacturer or supplier only if the footwear have been properly stored and have not been subjected to more than an original acceptance test and one retest.

10.2 Any acceptance test made by the purchaser, or the purchaser's designee, shall be performed within the first two months of the guarantee period unless otherwise specified.

## **11. Rejection**

11.1 Individual articles of footwear shall be rejected if they fail to meet the requirements of Sections 7, 8.1, and 12.

11.2 The entire lot or shipment of footwear shall be rejected if 5 % or more, but not less than two articles of footwear, in a lot or shipment fail to meet the requirements of 8.1.

11.3 The testing shall be terminated and the manufacturer or supplier notified if, during the course of testing, the footwear in a lot or shipment fail to meet the requirements of 8.1 as determined by the rejection criteria of 11.2. The manufacturer or supplier may in such a case require the purchaser to submit proof that the test procedure and equipment conform to this specification. When such proof has been furnished, the manufacturer or supplier may request that his representative witness the testing of additional footwear from the shipment.

11.4 All rejected material shall be returned as directed by the manufacturer, at his or the supplier's request, without being defaced by rubber stamp or other permanent marking. However, those articles of footwear punctured when tested in accordance with 8.1 shall be stamped, punched, or cut prior to being returned to the supplier to indicate that they lack the required dielectric property.

## **12. Packaging and Package Marking**

12.1 Each pair of footwear shall be packed in an individual container of sufficient strength to properly protect the footwear from damage in transit. The end of the container shall be marked with the name of the manufacturer or supplier, style, size, and color.

## **13. Keywords**

13.1 dielectric

*ASTM International takes no position respecting the validity of any patent rights asserted in connection with any item mentioned in this standard. Users of this standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, are entirely their own responsibility.*

*This standard is subject to revision at any time by the responsible technical committee and must be reviewed every five years and if not revised, either reapproved or withdrawn. Your comments are invited either for revision of this standard or for additional standards and should be addressed to ASTM International Headquarters. Your comments will receive careful consideration at a meeting of the responsible technical committee, which you may attend. If you feel that your comments have not received a fair hearing you should make your views known to the ASTM Committee on Standards, at the address shown below.*

*This standard is copyrighted by ASTM International, 100 Barr Harbor Drive, PO Box C700, West Conshohocken, PA 19428-2959, United States. Individual reprints (single or multiple copies) of this standard may be obtained by contacting ASTM at the above address or at 610-832-9585 (phone), 610-832-9555 (fax), or service@astm.org (e-mail); or through the ASTM website (www.astm.org).*